Steam Turbine Power Output

Power of a back-pressure or condensing steam turbine from the steam flow, inlet conditions, exhaust pressure and efficiencies (IAPWS-IF97).

Input parameters

Unit system: SI

Parameter	Value	Unit
Steam flow	10,000	kg/h
Inlet steam pressure (absolute)	45.000	bar
Inlet steam condition	Superheated at the temperature below	
Inlet steam temperature (superheated only)	400.00	°C
Exhaust pressure (absolute)	400.00	kPa
Turbine isentropic efficiency	75.000	%
Gearbox and generator efficiency	95.000	%

Calculated results

Parameter	Value	Unit
Electrical power	1,080.8	kW
Turbine shaft power	1,137.6	kW
Exhaust temperature	169.50	°C
Exhaust dryness (1 = dry or superheated)	100.00	%
Inlet enthalpy	3,205.6	kJ/kg
Exhaust enthalpy	2,796.0	kJ/kg
Isentropic exhaust enthalpy	2,659.5	kJ/kg

Formula and method

$$h_{2s} = h(p_2, s_1) \qquad h_2 = h_1 - \eta_i \left(h_1 - h_{2s}\right)$$

$$P_{sh} = \dot{m}_s \left(h_1 - h_2\right) \qquad P_{el} = \eta_g P_{sh} \qquad T_2,\ x_2 = f(p_2, h_2)$$

Variables

$\dot{m}_s$	steam flow	kg/s
p_1	inlet pressure, absolute	Pa
state	dry saturated or superheated inlet	–
T_1	inlet temperature (superheated)	K
p_2	exhaust pressure, absolute	Pa
η_i	turbine isentropic efficiency	–
η_g	gearbox and generator efficiency	–
P_{el}	electrical power	W
P_{sh}	turbine shaft power	W
T_2	exhaust temperature	K
x_2	exhaust dryness fraction	–
h_1	inlet enthalpy	J/kg
h_2	actual exhaust enthalpy	J/kg

h_{2s}	isentropic exhaust enthalpy	J/kg
s_1	inlet entropy	J/(kg·K)

Method and standards

Steady-flow energy balance across the turbine with the isentropic efficiency definition; inlet and exhaust states, including wet steam, from FireCAD's IAPWS-IF97 (backward equations h(p,s) and T(p,h)).

Assumptions and limits

- Single expansion, no extraction; steady flow; kinetic and potential energy changes neglected.
- Efficiencies are constant at the given load.

Report details

Report reference	FCC-W6EG-WY3H (the same inputs always give the same reference)
Generated	23 November 2026, 17:43 UTC
Calculator	Steam Turbine Power Output
Method last reviewed	11 November 2026
Software release	FireCAD Calc, release of 22 November 2026
Release checks	3 reference cases of this calculator, computed independently, are checked on every release

Results are for engineering estimation. Verify critical designs against the referenced standards and your own data.

This calculator online

https://calc.firecad.com/boilers-power-plant/steam-turbines/steam-turbine-power

Open this case on calc.firecad.com →

Reopens the calculator with the inputs of this report.